



CERTIFIKAT

Certificate of constancy of performance

0402 - CPR - SC0982-13

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011*
(the Construction Products Regulation or CPR), this certificate applies to the construction product

fixed firefighting system

Hose reels with semi-rigid hose

as specified in appendix to this certificate

**Product names: Type 1, Type 3, Type 3i, Type 3N, Type 4,
Type 4SEI60, Type 4G**

produced by or for

Presto Brandsäkerhet AB

Box 315

SE-641 23 KATRINEHOLM

Sweden

and produced in the manufacturing plant

Presto Brandsäkerhet AB, Spikgatan 3, SE-335 32 GNOSJÖ, Sweden

This certificate attests that all provisions concerning the assessment and verification
of constancy of performance and the performances described in Annex ZA of the standard

EN 671-1:2012

under system 1 are applied and that


the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2013-10-25 and will remain valid as long as the test methods and/or
factory production control requirements included in the harmonised standard, used to assess the performance
of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant
are not modified significantly.

Borås 2013-10-25

SP Technical Research Institute of Sweden
Certification, Notified Body No. 0402


Lennart Månsson
Certification Manager


Lennart Aronsson
Certification Officer

SP Technical Research Institute of Sweden

Postal address
Box 857
SE-501 15 Borås
SWEDEN

Phone / Fax
+46 10 516 50 00
+46 33 13 55 02

Reg. number
556464-6874

E-mail / Internet
info@sp.se
www.sp.se

This is issue 1. 3P04995
Swedish Notified Bodies are appointed by SWEDAC, the Swedish Board for Accreditation and
Conformity Assessment, under the terms of Swedish legislation.
This certificate may not be reproduced other than in full, except with the prior written approval
by SP.

**Hose reels with semi-rigid hose,
Type 1, Type 3, Type 3i, Type 3N, Type 4, Type 4SEI60, Type 4G**
for fixed installations to provide the occupants of a building
the means to control and extinguish a fire nearby

Product	Description	Hose Ø mm	Hose length max, m
Type 1	Wall mounted hose reel, with axial water supply.	19, 25	30
Type 3	Outside wall mounted hose reel cupboards.	19, 25	30
Type 3i	Insulated and electrical heated outside wall mounted hose reel cupboards.	19, 25	30
Type 3N	Outside wall mounted hose reel cupboards, exchange hose reel, partly mounted in wall.	19, 25	25
Type 4	In wall mounted hose reel cupboards.	19, 25	30
Type 4SEI60	In wall mounted hose reel cupboards, EI60 insulated.	19	30
Type 4G	In wall mounted hose reel cupboards, recessed crosswise.	19	30

All products are equipped with a shut off nozzle, type: TA Handfighter 2, nozzle Ø 7 mm for 19 mm hose and Ø 10 mm for 25 mm hose